CM MEASUREMENT RECORD ACCORDING TO WORKING INSTRUCTIONS

RETANOL' EKA/VIWA



Client		Construction Phase/Component/Floor/Apartment						
Construction Projekt			Component					
			REQUIREMENT: PCT MEA	SURING INSTI	RUCTION			
Date of application/laying			CM Service Measur *Explanation overleaf.		CM Approval Measurement*			
DOCUMENTATION								
Measurment No.1)		1	2		3			
Room No.								
Tester								
Date								
Test result								
Weight of sample g								
Manometer reading bar								
Water content ²⁾ %								
Temperature °C / Air humidity %								
Screed thickness mm								
¹⁾ Only required if screed was too moist during 1st measurement. ²⁾ From conversion table of manufacturer of CM device: corresponds to CM %.								
Floor covering		Floor heating/Temperature		Area				
Product	Dosage		Type of cement		Quantity			
Gravel supplier				Order according to DIN 1045-2				
Builder-owner/Client; Stamp/Signature		Site Manager/Architect; St	camp/Signature	Floor covering	g layer; Stamp/Signature			
PCT employee		Place/Date		Stamp/Signa	ature			



DECLARATION OF EXEMPTION CM MEASUREMENT

CM Service Measurement: Service measurements are performed in order to demonstrate the drying process of Retanol® screeds. Service measurements are not approval measurements and do not exempt the contractor commissioned with laying the floor covering from his due diligence obligation.

CM Approval Measurement: On request and on assignment PCT performs approval measurements on the object and assumes warranty for the test criterion of workability.

The declaration of exemption is granted in writing for every object. Declarations of exemption are never granted orally. Declarations of exemption are only granted if a CM measurement has been performed by an authorised PCT employee.

CM MEASURING INSTRUCTION FOR RETANOL® SCREEDS

- 1. Samples must be taken over the total cross-section of the screed to be measured. The top 2 mm must be removed in order that no surface moisture is also measured.
- 2. Fill the accurately weighed and crushed sample (50g) and the 4 steel balls into the CM pressure cylinder. Then hold the CM pressure cylinder in an inclined position and carefully slide in a calcium carbide vial.
- 3. Close the CM pressure cylinder with the lid and crush the CM vial by vigorous horizontal shaking. When beginning the measurement, please note the time with a suitable stopwatch.
- 4. Then carry out circular and horizontal movements with the CM pressure cylinder for two minutes to further crush the sample material and to mix it with the calcium carbide. Repeat this process for one minute after five minutes (circular movements). Read the value after 10 minutes. Prevent the steel balls from vertical knocking against the measuring head below the manometer. This will damage the measuring head and the measured values will be useless.

 Always wear gloves during the measurement!

Type of planned covering	3 – 8 days	9 – 28 days	29 - 56 days	from 57 days	
Stone and ceramic coverings in thin bed method	3,2 %	3,0 %	2,6%		
Textile floor coverings	3,2 %	3,0 %	2,6%		
Linoleum, rubber and similar without floor heating	3,2 %	3,0 %	2,6%		
Linoleum, rubber and similar on floor heating	3,0 %	2,8%	2,4%		
Parquet without floor heating	3,2 %	3,0%	2,6%	depending on the	
Parquet on floor heating	3,0 %	2,8%	2,4%	sorption isotherm	
Laminate without floor heating	3,2 %	3,0%	2,6%		
Laminate on floor heating	3,0 %	2,8%	2,4%		
Stone and ceramic coverings in thick bed method	4,2 %	4,0 %	3,6%		
Screed insulation and screed sealings	5,2 %	5,0 %	4,6 %		

Screeds laid on floor heating must be heated and cooled according to the heating record of the manufacturer before laying the covering. The workability of Retanol® screeds can only be determined by CM measurement. Other measuring methods are unsuitable and give incorrect results.

